



NOTES:

1. THE TEMP PROBE IS LOOP POWERED THROUGH THE 4-20 mA SIGNAL WIRING.
2. THE LOCAL DISPLAY IS BUILT INTO THE TEMP PROBE. IT SHALL GIVE THE READING IN DEGREES CELCIUS.
3. SEE CONTROL PANEL SUBMITTLE FOR DETAILED WIRING INSRUCTIONS.

TPS RESPONSIBILITY PER ASSEMBLY

PART #	ITEM	QTY
V10186	TEMPERATURE SENSOR	1
838-130	1"x1/2" RED BUSHING	1
	2" 316 SS BLIND FLANGE W/ COUPLING	1
	5/8"x2 1/2" 18-8 SS BOLTS	4
#70716	5/8" 18-8 SS NUTS	4
	2" NEOPRENE GASKET	1

CONTRACTOR RESPONSIBILITY PER ASSEMBLY

ITEM	QTY
4-20 mA SIGNAL WIRING	1

Thermal Process Systems
 1841 East Summit Street
 Crown Point, IN 46341

TEMP PROBE FLANGE
 Sheet: 1 OF 1
 Date: 1-30-2009
 Drawn By: KRM

